

CESI

Vs. rif.

Ns. rif. A2/012463/PeC/FP/mm

Data 23-04-2002

Messrs.

SACEM

B.P. 199 Z.I. Aeroport

TN-1080 TUNIS

TUNISIA

Att. Mr. MOHAMED CHTIOUI

Dear Sirs,

as per your kind requests, we confirm that the three-phase transformer 1000 kVA, 13.8/0.231 kV, serial number 80191, manufactured by SACEM, type SCECO, has been submitted to short-circuit tests in our laboratory on April 18, 2002.

After the tests, the visual inspection of the untanked transformer has been performed.

In the light of the IEC requirements for the judgement of the tests results, the transformer is deemed to have passed the tests successfully.

The test results will be reported in the official CESI Test Report MP-A2/011639.

Yours faithfully

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile

Pag 1/1